

PRESSURE VESSELS AND PIPING SYSTEMS: RELIABILITY, RISK AND SAFETY ASSESSMENT

F.A. Simonen

Pacific Northwest National Laboratory, Richland, Washington USA

Keywords: Pressure vessel, piping, reliability, risk, probabilistic risk assessment, fracture mechanics.

Contents

1. Introduction
 2. Failure Mechanisms and Failure Modes
 - 2.1 Failure Modes
 - 2.2. Failure Mechanisms
 3. Reliability and Risk
 4. Failure Frequency Estimation
 - 4.1. Advantages and Disadvantages of Alternative Methods
 5. Statistical Estimation Using Service Data
 6. Structural Reliability Models
 - 6.1. Reactor Pressure Vessel Codes
 - 6.2. Piping Reliability Codes
 7. Expert Judgment Elicitation
 8. Probabilistic Risk Assessment
 9. Role of Operation, Inspection and Maintenance
 10. Risk-Based In-service Inspection
 11. Probabilistic Design Methods
 12. Conclusion
- Glossary
Bibliography and Suggestions for further study
Biographical Sketch

Summary

Pressure vessels and piping systems are designed, fabricated, and operated to ensure very high levels of structural integrity, because the consequences of structural failures can be severe. Catastrophic ruptures can produce high-energy missiles, and cause damage to adjacent equipment and structures along with injuries and fatalities to workers and the public. Failure modes of a less catastrophic nature, such as leaks, can release hazardous and flammable materials that can also present significant hazards. While service experience over the last century shows an excellent record of reliability, efforts continue to improve and maintain the reliability of vessels and piping systems. This chapter describes methods to predict probabilities of failure and to quantify the consequences of such failures. These methods can be applied to vessels or piping systems taking into consideration component-specific design features, materials of construction, fabrication practices, operating stresses and temperatures, environmental factors, operating and maintenance practices, and in-service inspection programs.

Topics covered include: 1) probabilistic structural mechanics and fracture mechanics, 2) the role of probabilistic risk assessment evaluations, 3) application of failure event data from operating experience, 4) risk-informed in-service inspection, and 5) probabilistic design methods.

1. Introduction

The safety and reliability of pressure vessels and piping has been a public concern since the beginning of the industrial age. Failures of early steam boilers became widely reported as boiler explosions killed thousands of people per year and inflicted great damage to property. As a result, engineering organizations and government agencies developed and imposed legal requirements for engineering codes that applied to the design, construction, and operation of boilers and other high pressure vessels. In the 50 years after the American Society of Mechanical Engineering (ASME) was adopted, the number of deaths caused by explosions of properly operated boilers and pressure vessels was significantly reduced. Nevertheless, catastrophic failures still occur on rare occasions and other failures of a less significant nature (cracks and leaks) are more commonly reported. This chapter describes methods that can be used to estimate failure rates for vessels and piping systems. Also described are how such failure rates are used today in combination with evaluations of failure consequences using probabilistic risk assessment methods. Based on the author's experience, the examples will focus on nuclear power plant applications. However, the same approaches also apply to other industries such as petro-chemical, gas transmission pipelines, and to more common items such as heating boilers and water heaters.

Pressure vessels and piping systems are designed, fabricated, and operated to ensure a very high level of structural integrity because the consequences of structural failures can be severe. Even less catastrophic failures (such as leaks) can release hazardous and flammable materials that present significant hazards. Despite excellent safety records ongoing efforts are needed to ensure that the reliability of vessels and piping systems are maintained. This chapter describes methods developed over recent decades to predict frequencies of failure and to quantify the consequences of failures. Such methods can take into account vessel-specific design features, materials, fabrication practices, operating stresses, operating temperatures, environmental factors, operating practices, and in-service inspection programs. Topics include: 1) probabilistic structural mechanics and fracture mechanics, 2) the role of probabilistic risk assessment, 3) application of failure event data from plant operating experience, 4) risk-informed in-service inspection, and 5) probabilistic design methods.

2. Failure Mechanisms and Failure Modes

Before the reliability of a vessel or piping system is evaluated, it is first necessary to identify the potential failure mechanisms and failure modes of concern. One must also relate different failure modes to possible safety and/or economic consequences. Judgment is needed to focus evaluations on those failure scenarios having highest likelihoods of occurrence.

2.1 Failure Modes

There are many possible definitions (or degrees) of failure that may be of concern. Table 1 lists modes of failure that can be considered. These modes are presented in an increasing order of severity of consequence. The less severe modes (small cracks) are most likely to occur than the more severe modes (rupture). In addition, degradation if not detected and repaired will generally progress over time from a less severe mode (small crack) to more significant modes (leaking through-wall crack) and ultimately even to catastrophic failure.

Small crack
Local corrosion/wall thinning
Excessive distortion
Leaking Through-Wall Crack
Through-wall corrosion/wall thinning
Excessive Leakage
Fracture/catastrophic rupture

Table 1. Example Failure Modes

In some cases, concerns may be limited to catastrophic ruptures that would present the greatest threat to workers or to the general public. In other cases, evaluations may have a broader objective that considers unexpected degradation (corrosion, cracking, etc.) that would require repairs or replacements of components and thereby have an economic impact associated with repair costs and/or the loss of the productive use of the component. The consequences of small leaks can be very different depending on the situation. For a water storage vessel, the loss of a small volume of water could be of little concern; whereas, small leaks in vessels containing toxic or flammable materials could result in a large number of fatalities.

Table 1 lists failure modes in order of increasing consequences as follows:

- **Small Crack** – Degradation is sometimes detected in the form of a crack that does not fully penetrate the wall of the vessel or piping component. While such structural degradation by itself may pose no immediate safety consequences, it is prudent to take corrective actions to prevent future consequences. The need for repairs to the degraded component should be determined and implications for other similar components should be evaluated. Corrective actions could include an aggressive inspection program. In some cases, complete replacement of piping and vessels may be needed if the original designs and the selected materials are determined to be unsuitable for the operating conditions at the facility.
- **Local Corrosion and Wall Thinning** – While design methods usually specify a wall thickness that includes some allowance for corrosion over the life of the vessel and piping, the actual operating conditions may produce local rates of corrosion that exceed the expected rates. Inspections can and should detect corrosion before it fully penetrates the wall thickness and before any safety impacts result. As in the case of

cracking, corrective measures in the form of repairs and additional inspections should be implemented to ensure safe and economical operation.

- Excessive Distortion – A failure mode of concern may not involve penetration of the component wall, but may rather degrade the function of the component because of excessive deflection or distortion. For example, seating surfaces may become sufficiently misaligned to the degree that gasket leakage results.
- Leaking Through-Wall Crack – In some cases, even a small amount of leakage can have significant safety consequences, especially if the leaking fluid is highly toxic or flammable. In other cases, the release of otherwise non-hazardous fluids could impact the operation of nearby critical equipment by causing corrosion or electrical malfunctions.
- Through-Wall Corrosion/Wall Thinning – As for cracking, leakage even at relatively small rates can present significant safety or economic consequences.
- Excessive Leakage – Leakage rates can over time increase to levels that impact the function of a system or component. For example, a leak could eventually depressurize a critical system to the extent that it could no longer perform its intended function. In other cases, the leakage could create a water spray that could cause damage in the area adjacent to the leak.
- Fracture/Catastrophic Rupture – This most severe of consequences comes from sudden fracture or ruptures, which can occur without any prior leakage to give any warning of impending failure. The consequences of concern can be related to loss of function of the rupture component itself (e.g., loss of cooling water to process equipment) or can come from the extreme energy of the rupture event (e.g., high velocity missiles, blast waves, release of hot fluids, etc.).



Figure 1. Pipe that ruptured at nuclear power plant after severe wall thinning at inner surface caused by flow-assisted corrosion.

Figures 1–3 show some examples of ruptured piping. In each case, the failure involved the release of large amounts of energy along with significant economic impacts in terms of repair costs and shutdowns of important industrial facilities for extended periods of time. Figure 1 illustrates a failure associated with severe thinning of the pipe wall that caused a pipe rupture and fatalities to workers at a nuclear power plant. Figure 2 shows a ruptured pipe that had been in service for a large number of years. In this case, the corrosion damage to the older pipe was relatively small with the primary cause of failure being a sudden over-pressure from a water hammer event. Figure 3 shows

another ruptured pipe that failed at a coal-fired power plant. In this case, the degradation was not wall thinning but cracking by the mechanism of creep damage to an axial weld in the pipe that operated at a relatively high temperature. The catastrophic nature of the failures shown by Figures 1–3 serve to emphasize hazards associated with operation of pressure vessels and piping and the need to reduce failure frequencies to the lowest possible levels.



Figure 2. Steam pipe at municipal heating system that ruptured because of severe load imposed by water hammer event.



Figure 3. Pipe at coal-fired power plant that ruptured along axial weld because of high

temperature creep damage to weld.

2.2. Failure Mechanisms

Table 2 lists a number of failure mechanisms and other causes that are known to result in failures of pressure vessels and piping systems. This list is intended only to show examples and will not be discussed in detail. Many failures come from gradual material degradation (e.g., corrosion, fatigue cracking, wear, etc.) that occurs over time spans of many years before it advances to a stage sufficient to cause a structural failure (leak or rupture event). Metal fatigue is one common failure mechanism. Small-diameter piping is often subject to vibrational stresses that cause cracking. Fatigue failures of larger sizes of vessels and piping are more likely to come from cyclic thermal stresses such as at locations exposed to cyclic exposures to hot and cold fluids. Corrosion mechanisms are a particularly common cause of failures both in the form of widespread loss material (wall thinning) or as local attack such as pitting or cracking.

In other cases, a single short-term event (e.g., overpressure, extreme overheating, water hammer, etc.) can cause a sudden failure. Some loading events are natural occurrences such as earthquake loadings; whereas, other events come from human errors in operating and maintaining the facility such as from improper repairs and operation at pressures or temperatures over design limits. Pressurized systems are usually protected from excess pressures and temperatures by safety devices, but these devices can fail to function due to time-related degradation or improper installation or maintenance.

Operation at loads and/or pressures exceeding design limits
Operation at temperatures over design limits
Operation at temperatures below brittle fracture limits
Improper design and fabrication
Improper repairs and alterations
Structural damage from maintenance
Improper or degraded supports for components
Structural damage from external events (impact, crushing, etc.)
Excessive vibration
Improper or degraded overpressure protection
Material or welding defects
General corrosion
Flow-assisted corrosion
Wear (excessive maintenance)
Thermal fatigue cracking
Vibration fatigue cracking
Stress corrosion cracking
High-temperature creep
Long-term embrittlement
Loose or missing fasteners

Table 2. Example Failure Causes

3. Reliability and Risk

Terms related to reliability and risk must be clearly defined and understood within the context of vessel and piping integrity. Risk combines the concepts of probability of failure and consequences of failure using the definition

$$\text{Risk} = \text{Probability of Failure} \times \text{Consequences of Failure}$$

Probability is usually quantified as a failure frequency, which expresses the number of failure events that occur over a given time span. It is important to define the event of concern along with the time span of interest. An example definition would be rupture events per vessel per year of operation. Another example related to piping systems would be leaks per weld per year or leaks per meter of pipe per year. In other cases, it may be of interest to address reliability in a larger context such as failures per plant or failures per system.

The concept of failure frequency is applied to systems that operate on a continuing basis, as for example at electric power plants. However, other systems remain in a standby mode during normal operation and are needed only rarely to perform critical functions in times of emergencies. An example would be piping in a fire protection system. For such systems, risk evaluations express reliability in terms of probability of failure per demand rather than as failures per year.

Different failure events can have wide ranging consequences. Consequences can only be of an economic nature expressed in terms of dollars associated with loss of production plus the labor and materials for repairs. There can also be safety consequences from injuries to workers and/or the general public. For example, a small leak at a power plant would have no safety consequences and only minor economic consequences if the repair of the leak can be accomplished without interrupting the operation of the plant. On the other hand, the rupture of a pressure vessel or a large pipe could cause a large energy release, an explosion, or a fire with human deaths and injuries. In addition to severe safety consequences, ruptures can have major economic consequences totaling millions of dollars both from an extended shut down of a large production facility and major costs to replace the ruptured component along with repairs to damage inflicted on adjacent components and structures.

4. Failure Frequency Estimation

Failure frequencies for pressure boundary components must often be estimated to support Probabilistic Risk Assessments (PRAs) and other decision making purposes. Estimates are most often based on reported failures from past service experience and have focused on a system level rather than on the component level. Such estimates have limitations for predicting future performance and in identifying priorities for managing the integrity of specific components. Estimates based on service experience are better for evaluations of more common failure modes consisting of small leaks. Estimates for the frequencies of larger leaks and rupture events are, however, subject to larger

uncertainties if based solely on service experience.

Risk evaluations require realistic estimates of failure frequencies that apply to the specific combinations of materials, degradation mechanisms, and operating conditions. There are four basic approaches discussed below for estimating piping and vessel reliability:

- (1) Statistical estimation using service data,
- (2) Structural reliability analysis (SRA) based on probabilistic fracture mechanics,
- (3) Expert judgment/expert elicitation, and
- (4) Any combination of (1) through (3).

-
-
-

TO ACCESS ALL THE 26 PAGES OF THIS CHAPTER,
Visit: <http://www.desware.net/DESWARE-SampleAllChapter.aspx>

Bibliography and Suggestions for further study

ASME (2002). *Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications*, ASME RA-S-2002, American Society of Mechanical Engineers, New York. [Specifies the minimum requirements for a PRA that is used for a specific decision making application].

Balkey K.R. and FA Simonen (1999). Risk-Based Inspection Guidelines for Nuclear Power Plant Components, *Transactions of the 11th International Conference on Structural Mechanics in Reactor Technology*, Berlin, Germany: International Association for Structural Mechanics in Reactor Technology. [Describes the technical basis for the risk-informed inspection requirements that were later adopted by the ASME Section XI Code].

Bell C.D. and O.J.V. Chapman. (2003). Description of PRODIGAL, *NURBIM Report D4/Appendix F*, Rolls-Royce plc. [A probabilistic fracture mechanics code for welds in vessels and piping that was developed in the United Kingdom for naval reactor applications].

Bernsen S.A., F.A. Simonen and K.R. Balkey (2006). PRA and Risk-Informed Analysis, *Chapter 45 Companion Guide to the ASME Boiler and Pressure Vessel Codes – Second Edition – Volume 3*, ASME Press, New York, USA. [One of many chapters in a set of volumes that explains in the technical basis and provides guidance for users of ASME Code.]

Bishop B.A. (1993) Benchmarking of Probabilistic Fracture Mechanics Analyses of Reactor Vessels Subjected to Pressurized Thermal Shock Loading, EPRI Research Project 2975-5, Electric Power Research Institute, Palo Alto, CA. [Presents results of calculations performed to compare numerical results from several probabilistic fracture mechanics computer codes for a set of well defined example problems].

Bishop B.A. (1997). An Updated Structural Reliability Model for Piping Risk Informed ISI, *PVP-Vol. 346, Fatigue and Fracture - 1997, Volume 2*, American Society of Mechanical Engineers, New York. [Describes the development of the SRRA probabilistic fracture mechanics code].

Brickstad B. and W. Zang. (2001). NURBIT Nuclear RBI Analysis Tool, A Software for Risk Management of Nuclear Components, *Technical Report No 10334900-1*, DNV, Stockholm, Sweden. [A

probabilistic fracture mechanics code for pressure vessels and piping that was developed in Sweden for commercial power plant applications].

Brickstad B., O.J.V. Chapman, T. Schimpfke, H. Schulz, and A. Muhammed. (2004). Review and Benchmarking of SRM and Associated Software, *NURBIM Final Report D4*, Contract FIKS-CT-2001-00172, DNV, Stockholm. [Presents results of comparison calculations using several probabilistic fracture mechanic computer codes that serve to demonstrate different features of the codes].

Cheverton R.D. and D.G. Ball. (1984). *OCA-P: A Deterministic and Probabilistic Fracture-Mechanics Code for Applications to Pressure Vessels*, NUREG/CR-3618, prepared by Oak Ridge National Laboratory for the U.S. Nuclear Regulatory Commission. [The first probabilistic fracture mechanics code developed to calculate failure probabilities for reactor pressure vessels].

Dickson T.L. (1994). *FAVOR: A Fracture Mechanics Analysis Code for Nuclear Reactor Pressure Vessel, Release 9401*, ORNL/NRC/LTR/94/1. Martin Marietta Energy Systems, Inc., Oak Ridge National Laboratory. [Describes the development of a probabilistic fracture mechanics code for calculating failure probabilities for reactor pressure vessels].

Dickson T.L., P.T. Williams and S Yin. (2004). *Fracture Analysis of Vessels – Oak Ridge, FAVOR, v04.1, Computer Code: User's Guide*, NUREG/CR-6855, ORNL/TM-2004/245, October 2004. [The latest probabilistic fracture mechanics code developed to calculate failure probabilities for reactor pressure vessels].

Dillstrom P. (2003). *A Short Description of ProSACC, NURBIM Report D4/Appendix G*, DNV, Stockholm. [A probabilistic fracture mechanics code for pressure vessels and piping that was developed in Sweden for commercial power plant applications].

Gosselin S.R., F.A. Simonen, R.G. Carter, J.M. Davis and G.L. Stevens. (2005). Enhanced ASME Section XI Appendix L Flaw Tolerance Procedure, *PVP2005-71100, Proceedings of the 2005 ASME Pressure Vessels and Piping Conference*, July 17-21, 2005, Denver, Colorado. [Describes a method for predicting fatigue life based on damage tolerance approach that has been adopted by the ASME Section III Code].

Harris D.O., E.Y. Lim and D.D. Dedhia. (1981). *Probability of Pipe Fracture in the Primary Coolant Loop of a PWR Plant Volume 5: Probabilistic Fracture Mechanics Analysis - Load Combination Program Project 1 Final Report*, NUREG/CR-2189, Vol. 5, prepared by Lawrence Livermore National Laboratory for the U.S. Nuclear Regulatory Commission, Washington, DC. [The technical basis document for the PRAISE code that predicts leak and rupture probabilities for piping welds subject to fatigue cycles and seismic loads].

Harris D.O., D.D. Dedhia, E.D. Eason and S.D. Patterson. (1986). *Probability of Failure in BWR Reactor Coolant Piping: Probabilistic Treatment of Stress Corrosion Cracking in 304 and 316NG BWR Piping Weldments*, NUREG/CR-4792 v3, U.S. Nuclear Regulatory Commission, Washington, DC. [The technical basis document for an improved version of the PRAISE code that predicts failure probabilities for piping welds subject to stress corrosion cracking].

Harris D.O. and D.D. Dedhia. (1992). *Theoretical and User's Manual for pc-PRAISE, A Probabilistic Fracture Mechanics Computer Code for Piping Reliability Analysis*, NUREG/CR-5864, U.S. Nuclear Regulatory Commission, Washington, DC. [A version of mainframe PRAISE code that was adapted for use on personal computers.]

Harris D.O. and D.D. Dedhia. (1998). *WinPRAISE 98 PRAISE Code in Windows, April 1998*. [A version of the PRAISE code that allows for interactive entries of input data].

Khaleel M.A. and F.A. Simonen. (1994a). The Effects of Initial Flaw Sizes and In-service Inspection on Piping Reliability, *ASME PVP Vol. 288, Service Experience and Reliability Improvement: Nuclear, Fossil and Petrochemical Plants, Vol. 1*, pp. 95-107. [Application of the PRAISE code to show how probability of detection and frequencies of inspections can reduce failure probabilities of piping welds].

Khaleel M.A. and F.A. Simonen. (1994b). A Parametric Approach to Predicting the Effects of Fatigue on Piping Reliability, *ASME PVP Vol. 288, Service Experience and Reliability Improvement: Nuclear, Fossil and Petrochemical Plants, Vol. 1*, pp. 117-125. [Application of the PRAISE code to show how the magnitude and frequency of fatigue stresses related to failure probabilities of piping welds].

Khaleel M.A., F.A. Simonen, D.O. Harris and D. Dedhia. (1995). The Impact of Inspection on Intergranular Stress Corrosion Cracking for Stainless Steel Piping, *ASME PVP Vol. 266/SERA-Vol.3, Risk and Safety Assessment: Where is the Balance*, pp. 411-422. [Application of the PRAISE code to show how probability of detection and frequencies of inspections can reduce failure probabilities of piping welds subject to stress corrosion cracking].

Khaleel M.A. and F.A. Simonen. (2000a). Effects of Alternative Inspection Strategies on Piping Reliability, *Nuclear Engineering and Design*, Vol. 197, pp. 115-140. [Application of the PRAISE code to show how probability of detection and frequencies of inspections can reduce failure probabilities of piping welds].

Khaleel M.A., F.A. Simonen, H.K. Phan, D.O. Harris, and D.D. Dedhia. (2000b). Fatigue Analysis of Components for 60-Year Plant Life, NUREG/CR-6674, PNNL-13227, prepared by Pacific Northwest National Laboratory for U.S. Nuclear Regulatory Commission, Washington, DC. [Application of the PRAISE code to compare failure probabilities at 40 and 60 years of plant operation for piping subject to fatigue cycling].

Lydell B.O.Y., E. Mathet and K. Gott. (2004). Piping Service Life Experience in Commercial Nuclear Power Plants: Progress with the OECD Pipe Failure Data Exchange Project, *Proceedings of the 2004 ASME Pressure Vessels and Piping Conference*, American Society of Mechanical Engineers, New York. [A discussion of a data base on piping failures reported a commercial nuclear power plants].

Lydell B.O.Y. and A. Olsson. (2006). *Reliability Data for Piping Components in Nordic Nuclear Power Plants*, 2005153-M-003 Rev. A1, Relcon AB, Malmö, Sweden, March 2, 2006. [A discussion of a data base on piping failures reported a commercial nuclear power plants].

Mohammed A.A. (2003). *A Short Description of STRUEL, NURBIM Report D4/Appendix H, TWI*. [A probabilistic fracture mechanics code for welds in vessels and piping that was developed in Germany].

Mosleh A. et al. (1987). *Methods for Elicitation and Use of Expert Opinion in Risk Assessment*, NUREG/CR-4962, U.S. Nuclear Regulatory Commission, Washington, DC. [A handbook type of document to guide the application of expert judgment to nuclear power plant applications.]

NASA. (2002). *Probabilistic Risk Assessment Procedures and Guide for NASA Managers and Practitioners, version 1.1*, prepared for Office of Safety and Mission Assurance, National Aeronautics and Space Administration Headquarters, Washington, DC, USA. [This 323 page instructional document is available to the public through the internet from the website www.hq.nasa.gov/office/codeq/doctree/praguide.pdf].

NRC. (1975). *Reactor Safety Study: An Assessment of Accident Risks at U.S. Commercial Nuclear Power Plants*, Technical Report WASH-1400, U.S. Nuclear Regulatory Commission, Washington, DC. [A landmark study that was used to evaluate the public risk from commercial nuclear power plants].

NRC. (1983). *PRA Procedures Guideline: A Guide to the Performance of Probabilistic Risk Assessment for nuclear Power Plants*. NUREG/CR-2300. Washington D.C. Nuclear Regulatory Commission. [A document prepared by the USNRC to provide guidance to the nuclear power industry for developing a plant specific PRA].

NRC. (1990). *Severe Accident Risks: An Assessment of Five U.S. Nuclear Power Plants*, NUREG-1150, U.S. Nuclear Regulatory Commission, Washington, DC. [A major study supported by the USNRC to demonstrate the use of PRA methods to a representative sample of commercial nuclear power plants].

NRC. (1991). *Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants*, 10 CFR 50.65. U.S. Nuclear Regulatory Commission, Washington DC. [A regulatory document that requires commercial nuclear power plant to apply insights from risk calculations to guide the maintenance of nuclear power plants].

OECD Nuclear Energy Agency. (2005). OECD-NEA Piping Failure Data Exchange Project (OPDE), *Workshop on Database Applications*, OPDE/SEC(2004)4, Issy-les-Moulineaux, France. [A discussion of a data base on piping failures reported a commercial nuclear power plants].

OECD Nuclear Energy Agency. (2006). *OPDE 2006:1 Coding Guideline (OPDE-CG) & OPDE User Instruction, PR01 Version 02*, Issy-les-Moulineaux (France). [Guidance on the use of a data base on piping failures reported a commercial nuclear power plants].

Poloski J.P., D.G. Marksberry, C.L. Atwood and W.J. Galyean. (1999). *Rates of Initiating Events at U.S. Nuclear Power Plants: 1987-1995*, NUREG/CR-5750, prepared by Idaho National Engineering Laboratory for U.S. Nuclear Regulatory Commission, Washington, DC. [A compilation and evaluation of reported events at commercial nuclear power plants including failures by leakage and rupture of piping].

Rudland D.L. H. Xu, G. Wilkowski, P. Scott, N. Ghadiali and F. Brust. (2006a). Development of a New Generation Computer Code (PRO-LOCA) for the Prediction of Break Probabilities for Commercial Nuclear Power Plants Loss-of-Coolant Accidents, *Proceeding of the ASME Pressure Vessels and Piping Conference, July 23-27, 2006*, Vancouver, British Columbia, American Society of Mechanical Engineers, New York, New York. [A paper on the early development of the PRO-LOCA probabilistic fracture mechanics codes for calculating failure frequencies for piping at commercial nuclear power plants].

Schimpfke T. (2003). *A Short Description of the Piping Reliability Code PROST, NURBIM Report D4/Appendix C*, GRS. [A probabilistic fracture mechanics code for welds in piping that was developed in Germany].

Simonen F.A., K.I. Johnson, A.M. Liebetau, D.W. Engel and E.P. Simonen. (1986). *VISA-II - A Computer Code for Predicting the Probability of Reactor Pressure Vessel Failure*, NUREG/CR-4486, prepared by Pacific Northwest National Laboratory for the U.S. Nuclear Regulatory Commission. [A probabilistic fracture mechanics code developed by the USNRC to calculate failure probabilities for reactor pressure vessels].

Simonen F.A., D.O. Harris and D.D. Dedhia. (1998). Effect of Leak Detection on Piping Failure Probabilities, *Fatigue Fracture and Residual Stress*, ASME PVP-Vol. 373, pp. 105-113. [Application of the PRAISE code to show how leak detection can reduce failure probabilities of piping welds].

Simonen F.A. and M.A. Khaleel. (1998a). On the Contribution of Buried Flaws to Piping Failure Probabilities, *Fatigue Fracture and Residual Stress*, ASME PVP-Vol. 373, pp. 69-75. [Application of the PRAISE code that compares the contributions to piping failure probabilities from inner surface flaws to the contributions from subsurface buried flaws].

Simonen F.A. and M.A. Khaleel. (1998b). Effects of Flaw Sizing Errors on the Reliability of Vessels and Piping, *ASME Journal of Pressure Vessel Technology*, Vol. 120, pp. 365-373. [Application of the PRAISE code that shows that flaw sizing errors is not as important to piping reliability as the failure to detect flaws].

Tregoning R., L. Abramson and P. Scott. (2005). *Estimating Loss-of-Coolant-Accident (LOCA) Frequencies Through the Elicitation Process*, NUREG-1829 (June 30, 2005), U.S. Nuclear Regulatory Commission, Washington, DC. [A large-scale effort to apply current knowledge to estimate piping failure frequencies that used an international panel of experts].

Westinghouse Owners Group (1997). *Application of Risk-Informed Methods to Piping In-service Inspection, Topical Report*, WCAP-14572, Rev. 1 Westinghouse Energy Systems. [A trial application of the risk-based based methods for in-service inspection of piping systems developed for the ASME Section XI Code].

Biographical Sketch

Fredric Simonen, a mechanical engineer, graduated in 1966 with a Ph.D. degree in Engineering Mechanics from Stanford University located at Stanford, California, USA. He is presently a Laboratory Fellow (retired) in the Computational Mechanics Group at Pacific Northwest National Laboratory in Richland, Washington, USA. Since joining the Pacific Northwest National Laboratory in 1976, and before that at the Battelle Columbus Division beginning in 1966, Dr. Simonen has worked in the areas of fracture mechanics and structural integrity. His research has addressed the safety and reliability of nuclear pressure vessels and piping as well as other industrial and aerospace structures and components. Since the early 1980s, he has lead several studies for the U.S. Nuclear Regulatory Commission of the effects of pressurized thermal shock on the failure probability of reactor pressure vessels. This work has advanced

the technology of probabilistic fracture mechanics and methods for estimating the number and sizes of flaws in vessel welds. During the 1990s, Dr. Simonen was a leader on the behalf of NRC and the American Society of Mechanical Engineers in the implementation of risk-informed methods for the inspection of nuclear piping systems. He has published over 200 papers, articles, and reports in the open literature. Dr. Simonen is a member of the American Society of Mechanical Engineers and has served on numerous ASME committees and codes and standards bodies.